

San Dieguito Water District ANNUAL WATER QUALITY REPORT

WATER QUALITY TEST RESULTS
FROM 2012

R.E. BADGER

FILTRATION PLANT

What Is This Report About?

This brochure is a snapshot of the quality of the water that the San Dieguito Water District provided in 2012. Included are details about where your water comes from, what it contains, and how it compares to standards set by regulatory agencies.

Where Does My Water Come From?

The San Dieguito Water District and Santa Fe Irrigation District jointly own and operate the R.E. Badger Filtration Plant. The plant treats both imported and local water. Imported water is delivered by pipeline from Lake Skinner located in the City of Hemet. Lake Skinner is a blend of water imported by the Metropolitan Water District of Southern California from the Colorado River and the Sacramento River Delta.

Local water originates from Lake Hodges. Lake Hodges water is either transferred to the San Dieguito Reservoir through a small aqueduct and then to the treatment plant, or directly to the treatment plant via the Cielo Pump Station.

Source Water Assessment

Local water supplies are considered most vulnerable to agricultural and urban/storm runoff. A copy of the R. E. Badger Filtration Plant Watershed Sanitary Survey is available for review at the treatment plant. If you have any questions about this report, please call Cor Shaffer, Operations Manager, or Tim Bailey, Water Quality Analyst at (858) 756-2569.

In December 2002, Metropolitan Water District of Southern California completed its source water assessment of our imported water from the Colorado River and State Water Project supplies. Colorado River supplies are considered to be most vulnerable to recreation, urban/storm water runoff, increasing urbanization in the watershed and wastewater. State Water Project supplies are considered to be most vulnerable to urban/storm water runoff, wildlife, agriculture, recreation and wastewater. A copy of the assessment can be obtained by contacting Metropolitan by phone at (213) 217-6850.

Is My Water Safe?

Yes! Last year, as in years past, your tap water not only met, but exceeded all U.S. Environmental Protection Agency (USEPA) and state drinking water health standards. The San Dieguito Water District vigilantly safeguards the water supplies and is committed to providing high quality drinking water to its customers.

All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the USEPA's Safe Drinking Water Hotline (1-800-426-4791).

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers.

USEPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the Safe Drinking Water Hotline (1-800-426-4791).

Español (Spanish) - Este informe contiene información muy importante sobre su agua potable. Tradúzcalo o hable con alguien que lo entienda bien. Para asistencia en español, llame (760) 633-2709.

Terms Used In This Report

Maximum Contaminant Level (MCL): The highest level of a contaminant that is allowed in drinking water. Primary MCLs are set as close to the PHGs (or MCLGs) as is economically and technologically feasible. Secondary MCLs are set to protect the odor, taste, and appearance of drinking water.

Maximum Contaminant Level Goal (MCLG): The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are set by the U.S. Environmental Protection Agency (USEPA).

Public Health Goal (PHG): The level of a contaminant in drinking water below which there is no known or expected risk to health. PHGs are set by the California Environmental Protection Agency.

Maximum Residual Disinfectant Level (MRDL): The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG): The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Primary Drinking Water Standards (PDWS): MCLs and MRDLs for contaminants that affect health along with their monitoring and reporting requirements, and water treatment requirements.

Secondary Drinking Water Standards (SDWS): MCLs for contaminants that affect taste, odor, or appearance of the drinking water. Contaminants with SDWSs do not affect the health at the MCL levels.

Treatment Technique (TT): A required process intended to reduce the level of a contaminant in drinking water.

Regulatory Action Level (AL): The concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system must follow.

Variances and Exemptions: Department permission to exceed an MCL or not comply with a treatment technique under certain conditions.

NTU: nephelometric turbidity unit

TON: threshold odor number

µS/cm: micro Siemens per centimeter

ND: not detectable at testing limit

ppm: parts per million or milligrams per liter (mg/L)

ppb: parts per billion or micrograms per liter (ug/L)

pCi/L: picocuries per liter (a measure of radiation)

TOC: total organic carbon

THMs: trihalomethanes

HAAs: haloacetic acids

N/A: not applicable

The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the USEPA's Safe Drinking Water hotline(1-800-426-4791) or on the USEPA's website <http://water.epa.gov/drink/standards/hascience.cfm>.

TABLE 1 - SAMPLING RESULTS SHOWING THE DETECTION OF COLIFORM BACTERIA

Microbiological Contaminants	Highest No. of detections	No. of months in violation	MCL	MCLG	Typical Source of Bacteria
Total Coliform Bacteria	1 (in a month)	0	More than 5% of total samples in a month with a detection	0	Naturally present in the environment
Fecal Coliform or E. coli	0 (in the year)	0	A routine sample and a repeat sample detect total coliform and either sample also detects fecal coliform or E. coli	0	Human and animal fecal waste

TABLE 2 - SAMPLING RESULTS SHOWING THE DETECTION OF LEAD AND COPPER

Lead and Copper (2010)	No. of samples collected	90 th percentile level detected	No. sites exceeding AL	AL	PHG	Typical Source of Containment
Lead (ppb)	30	2.0	0	15	0.2	Internal corrosion of household water plumbing systems; discharges from industrial manufacturers; erosion of natural deposits
Copper (ppm)	30	0.31	0	1.3	0.3	Internal corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives

TABLE 3 - SAMPLING RESULTS FOR SODIUM AND HARDNESS

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	MCL	PHG (MCLG)	Typical Source of Contaminant
Sodium (ppm)	2012	111	97 - 130	none	none	Salt present in the water and is generally naturally occurring
Hardness (ppm)	2012	267	230 - 310	none	none	Sum of polyvalent cations present in the water, generally magnesium and calcium, and are usually naturally occurring
Hardness (grains/gal)	2012	15.6	13.5 - 18.1	none	none	Sum of polyvalent cations present in the water, generally magnesium and calcium, and are usually naturally occurring

TABLE 4 - DETECTION OF CONTAMINANTS WITH A PRIMARY DRINKING WATER STANDARD

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	MCL [MRDL]	PHG (MCLG) [MRDLG]	Typical Source of Contaminant
Uranium (pCi/L)	2007	0.625	ND - 2.5	20	0.43	Erosion of natural deposits
Radioactivity (Beta)	2007	1.47	ND - 5.9	50	0	Decay of natural and man-made deposits
Combined Radium (pCi/L)	2007	0.23	ND - 0.90	5	0	Erosion of natural deposits
Aluminum (ppm)	2012	0.002	ND - 0.024	1	0.6	Erosion of natural deposits; residue from some surface water treatment processes.
Arsenic (ppb)	2012	1.25	ND - 2.1	10	0.004	Erosion of natural deposits; runoff from orchards; glass and electronics production wastes
Barium (ppm)	2012	0.051	0.043 - 0.058	1	2	Discharges of oil drilling wastes and from metal refineries; erosion of natural deposits
Chromium (ppb)	2012	1.70	ND - 6.8	50	100	Discharge from steel and pulp mills and chrome plating; erosion of natural deposits
Fluoride (ppm)	2012	0.19	0.17 - 0.21	2.0	1	Erosion of natural deposits; water additive that promotes strong teeth; discharge from fertilizer and aluminum factories
Nitrate as NO3 (ppm)	2012	0.09	ND - 0.36	45	45	Runoff and leaching from fertilizer use; leaching from septic tanks and sewage; erosion of natural deposits
Selenium (ppb)	2012	1.53	ND - 6.10	50	30	Discharge from petroleum, glass, and metal refineries; discharge from mines and chemical manufacturers; runoff from live stock lots (feed additive)
Total THMs (ppb)	2012	61.04	35.0 - 78.0	80	-	By-product of drinking water disinfection
Total HAA5 (ppb)	2012	14.86	5.4 - 21.0	60	-	By-product of drinking water disinfection
Chlorite (ppm)	2012	0.42	0.20 - 0.55	[1.0]	[0.05]	By-product of drinking water disinfection
Chlorate (ppm)	2012	0.386	0.26 - 0.58	-	-	By-product of drinking water disinfection
Chloramines (ppm)	2012	1.91	1.5 - 2.49	[4.0]	[4.0]	Drinking water disinfectant added for treatment
Chlorine Dioxide (ppb)	2012	10	ND - 100	[800]	[800]	Drinking water disinfectant added for treatment
DBP Precursors (ppm TOC)	2012	4.783	2.98 - 6.77	TT	TT	Various natural and man-made sources

TABLE 5 - DETECTION OF CONTAMINANTS WITH A SECONDARY DRINKING WATER STANDARD

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	MCL	PHG (MCLG)	Typical Source of Contaminant
Aluminum (ppb)	2012	2.0	ND - 24	200	N/A	Erosion of natural deposits; residue from some surface water treatment processes.
Color (Units)	2012	4.5	2.0 - 5.8	15	N/A	Naturally-occurring organic materials
Copper (ppm)	2012	0.002	ND - 0.005	1	N/A	Internal corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
Odor (Units)	2012	1	1 - 3	3	N/A	Naturally-occurring organic materials
Turbidity (NTU)	2012	0.04	0.02 - 0.49	5	N/A	Soil runoff
Total Dissolved Solids (ppm)	2012	627	560 - 710	1000	N/A	Runoff/leaching from natural deposits
Specific Conductance (μ S/cm)	2012	1057	930 - 1200	1600	N/A	Substances that form ions when in water; seawater influence
Chloride (ppm)	2012	152	120 - 200	500	N/A	Runoff/leaching from natural deposits; seawater influence
Sulfate (ppm)	2012	160	130 - 170	500	N/A	Runoff/leaching from natural deposits; industrial wastes

TABLE 8 - SAMPLING RESULTS SHOWING TREATMENT OF SURFACE WATER SOURCES

Treatment Technique ^(a) (Type of approved filtration technology used)	Conventional Filtration
Turbidity Performance Standards ^(b) (that must be met through the water treatment process)	<u>Turbidity of the filtered water must:</u> 1 - Be less than or equal to 0.3 NTU in 95% of measurements in a month. 2 - Not exceed 1.0 NTU for more than eight consecutive hours. 3 - Not exceed 5.0 NTU at any time.
Lowest monthly percentage of samples that met Turbidity Performance Standard No. 1.	99.5%
Highest single turbidity measurement during the year	0.49 NTU
Number of violations of any surface water treatment requirements	None

(a) A required process intended to reduce the level of a contaminant in drinking water.


(b) Turbidity (measured in NTU) is a measurement of the cloudiness of water and is a good indicator of water quality and filtration performance. Turbidity results which meet performance standards are considered to be in compliance with filtration requirements.





What Might Be In My Drinking Water?


The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radio-active material, and can pick up substances resulting from the presence of animals or from human activity.


Contaminants that may be present in source water include:

 **Microbial contaminants**, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.

 **Inorganic contaminants**, such as salts and metals, that can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.

 **Pesticides and herbicides**, that may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.

 **Organic chemical contaminants**, including synthetic and volatile organic chemicals, that are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, agricultural application, and septic systems.

 **Radioactive contaminants**, that can be naturally-occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, the USEPA and the California Department of Public Health (Department) prescribe regulations that limit the amount of certain contaminants in water provided by public water systems. Department regulations also establish limits for contaminants in bottled water that provide the same protection for public health.

Tables 1, 2, 3, 4, 5 and 8 list all of the drinking water contaminants that were detected during the most recent sampling for the constituent. The presence of these contaminants in the water does not necessarily indicate that the water poses a health risk. The Department allows us to

monitor for certain contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of the data, though representative of the water quality, are more than one year old.

Lead

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. The San Dieguito Water District is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at www.epa.gov/safewater/lead.

Water Use Efficiency Programs

The San Dieguito Water District offers conservation outreach, education and incentives. Visit our website for new programs, classes and information: www.sdwd.org/conserve. For conservation questions, e-mail us at conserve@sdwd.org, or call (760) 633-2676.

WaterSmart Checkups

Help control irrigation costs at your home or business with a checkup from a certified irrigation specialist. This is a great way to increase efficiency and get site-specific recommendations. Single-family home checkups also include recommendations to increase indoor water-use efficiency. There is no obligation, and it's free! Visit watersmartcheckup.org to apply.

Commercial - Business

Water Use Efficiency

There are rebates available through www.socalwatersmart.com for water efficient landscape irrigation and business-specific indoor devices. The USEPA WaterSense at Work best management practices provide comprehensive guidelines to commercial, industrial and institutional organizations. The web version of this guide helps you navigate to business specific ideas for conserving our most precious natural resource, water. www.epa.gov/watersense/commercial/bmps.html.

Residential Program

Rebates are available for high efficiency clothes washers, smart irrigation controllers and rotating sprinkler nozzles through www.socalwatersmart.com/.

To assist our residential customers, SDWD is now participating in www.FreeSprinklerNozzles.com.

Visit the website for information and to register for a voucher for up to 25 free sprinkler nozzles for your property. The program tutorials will guide you to better understand your existing irrigation system components and needs. After completing the brief training, you will receive the voucher. This program helps to give you the confidence to purchase, install and adjust the appropriate nozzles on your own. Visit www.FreeSprinklerNozzles.com for more details on this program. Incentives will be available until SDWD funding is exhausted.

WaterSmart Turf Replacement Program

The San Diego County Water Authority offers a \$1.50 per square foot incentive to eligible residential and commercial customers who replace existing, water-intensive turf grass with alternative, water-efficient landscaping. For full program requirements, landscape criteria, and more details about the program, visit the website at www.turfreplacement.watersmartd.org. The funding for this program has been made available through California Department of Water Resources and Bureau of Reclamation grants. Incentives will be distributed on a first-come, first-served basis until exhausted.

Incentive programs are subject to change and other programs may become available during the year. For program information and updates, visit www.sdwd.org/conserve.

Resources for Home Water Use Efficiency

Visit our website, www.sdwd.org/conserve, for programs, ideas and classes to help you save water and money. For great conservation ideas around the home and outdoors, visit www.watersmartd.org.

Recycled Water

The San Dieguito Water District and San Elijo Joint Powers Authority (SEJPA) have partnered to bring recycled water to the area's golf courses, homeowner's associations, parks, schools, parkways and medians. In 2012, approximately 188 million gallons of recycled water was provided to the District's customers. By utilizing recycled water, we are making the most of one of Southern California's most precious resources – water. Using recycled water helps the environment and is an important part of diversifying the local water supply.

If you would like to know more about the availability of recycled water in your area, please call us at (760) 633-2709.





San Dieguito Water District
160 Calle Magdalena
Encinitas, CA 92024

PRSRT STD
U.S. POSTAGE
PAID
SAN DIEGO, CA
PERMIT NO.700



San Dieguito Water District
160 Calle Magdalena
Encinitas, CA 92024
(760) 633-2709



 **Find us on Facebook!**
www.sdwd.org

The San Dieguito Water District supplies water to Old Encinitas, Cardiff, Leucadia and parts of New Encinitas within the City of Encinitas. It covers 8.9 square miles and generally lies west of El Camino Real to the ocean. When the City of Encinitas was incorporated, the City Council of the City of Encinitas became the governing board of the Water District.

Getting Involved: The San Dieguito Water District Board of Directors meets on the third Wednesday of each month at 5:30 pm at Encinitas City Hall. City Hall is located at 505 South Vulcan Avenue, Encinitas. Please feel free to participate in these meetings.